


OPERATION PROCESSING IN POWER INTERRUPTION DETECTION (DETECTION VOLTAGE LEVEL 80%)		SELECT
1	ABOUT 20ms OR MORE DETECTS THE POWER FAILURE.	MAJOR FAULT STOP ○
2	ABOUT 5ms OR MORE DETECTS THE POWER FAILURE.	THE FREERUN STOP
3	ABOUT 300ms OR MORE DETECTS THE POWER FAILURE (300ms DRIVING CONTINUANCE)	MAJOR FAULT STOP THE FREERUN STOP

※ THE FREERUN STOP IS INVERTER RESTART IN VOLTAGE RECOVERY.

	A01	A02	A03	A04
CODE				
OFFSET				
GAIN				



10E10B14B
11#01#20E

Revisions	Drawn	2010-10-15	Z. HUA/T. TAK.	Approved
	Checked	2010-10-15	K. KASAGAMI	
	Fuji Electric Systems Co.,Ltd.			

Title	INVERTER CUBICLE		Ref. Drawing No.	HJ405668	20
	CONTROL STACK				
				HIJ49063FZ000	20